



FORM B 13.3

## FIRE SAFETY CERTIFICATE RENEWAL (FSCR)

(See Rule 25)

Fire Safety Certificate Approval (FSCA) No. FSCA/O/RFORAJ/2024/00050190

Date: 23/04/2024

FSC Safety Certificate Renewal (FSCR) No. FSCA/O/RFORAJ/2024/00050190/R1

Building Occupancy/Category: Educational (non-residential)

To,

PATADIA MAYUR KANAIYALAL

-- NANA KAPAYA MUNDRA Mundra Kachchh 370415

Fire Region: Rajkot RFO

Mobile No: 9687605239 Email ID: Amrit.aps@adanischools.ac.in

This has reference to your Application No. **2024/00050204** dated 06/03/2024 for **Fire Safety Certificate Renewal (FSCR)** for the building/premise **ADANI PUBLIC SCHOOL (name of the Building/ Project)**, as per below mentioned details:

1. TP Number:
2. FP Number:
3. Survey Number: 23 AND 73
4. Village Name: MUNDRA
5. Name of Block(s): ADANI PUBLIC SCHOOL

The building/premise was inspected on **23/04/2024** and all fire prevention, life safety and fire protection measures provided were found to be in proper and effective working condition. There are no changes in building/premise use or occupancy or in building design or structure.

Further, the following activities (as applicable) have been carried out towards meeting requirements of GFP&LSM Act-2013, GFP&LSM Rules-2014 & GFP&LSM Regulations-2023 as amended, or the then applicable GDCR:

1. Emergency drill was carried out on **23/04/2024**
2. Six monthly inspection was done on **23/04/2024**

The Fire Safety Certificate is renewed for a period of **two (2)** years upto **23/04/2026** in accordance with GFP&LSM Act-2013, GFP&LSM Rules-2014 & GFP&LSM Regulations-2023 and their amendments.



*Kamlesh*

Principal  
Adani Public School

Mundra Kutch - 370421

FSCA/O/RFORAJ/2024/00050190/R1

### Digitally Verified

Digitally verified by: Kamlesh Matiya  
Fire Safety Officer - General (FSO-G)  
2021/000021

Date: 23/04/2024  
Time: 11:06 AM



This is a digitally verified certificate, hence doesn't require physical signature. To validate authenticity of this certificate, scan the QR code or search the certificate details in appropriate section at [www.gujfiresafetycop.in](http://www.gujfiresafetycop.in).

Please note that, apart from renewal, the building needs to be inspected every six months and a mock fire and emergency drill also needs to be conducted every six months. If there is a delay in scheduled inspection or mock drill, penalty shall be imposed. The Fire Safety Certificate renewal should be done timely after two years to avoid penalties.