



BHUJ NAGAR SEVA SADAN-BHUJ

Dr. Jayant Khatri Marg - Bhuj



NO.BNP/FIRE/ 2430 /2021

DATE: - 16/01/2021

TO,
ADANI PUBLIC SCHOOL
NANA KAPAYA,
MUNDRA - KUTCH.

SUB.: ISSUE FIRE NOC

THIS IS TO CERTIFY THAT THE "ADANI PUBLIC SCHOOL, NANA KAPAYA, MUNDRA - KUTCH." COMPLIES WITH THE REQUIREMENTS OF FIRE SAFETY STANDERS AND THE FIRE SAFETY MEASURES INSTALLED AT THESE PREMISES ARE ADEQUATE.

THE FIRE NOC IS HEREBY GRANTED WHICH IS VALID UP TO 15.01.2022. THE "NOC" SHALL BE VALID SUBJECT TO THE FOLLOWING CONDITIONS:

- ANNUAL MAINTENANCE CONTRACT HAS BEEN GIVEN
- THERE SHALL BE SUFFICIENT NUMBERS OF EMPLOYEES TRAINED IN FIRE FIGHTING EQUIPMENT AND EMERGENCY CONTROL.
- ALL SHED ARE PROTECTED BY HYDRANT SYSTEM AND FIRE EXTINGUISHERS.
- THERE SHALL BE FIRE WATER STORAGE OFF AT-LEAST 10000 KL.

FURTHER, THE FACTORY MANAGEMENT SHALL RESPONSIBLE FOR THE FOLLOWING:

CONDITION:

1. FACTORY MANAGEMENT IS RESPONSIBLE FOR ANY INCIDENT OF FIRE.
2. MAINTAINING FIRE FIGHTING EQUIPMENT DAILY BASIS.
3. PROVIDE INSURANCE.
4. N.O.C VALID FROM 16.01.2021 TO 15.01.2022 FOR THE PERIOD OF ONE YEAR.
5. IN CASE OF ANY AMENDMENT IN GUJARAT FIRE PREVENTION AND LIFE SAFETY MEASURE ACT 2013 SHALL BE APPLICABLE TO THE SAID FACTORY.

THE BREACH OF ANY OF THE ABOVE CONDITIONS SHALL AUTOMATICALLY RENDER THIS CERTIFICATE INVALID AND CANCELLED AND WILL RENDER THE CONCERNED OWNER/DIRECTOR/GENERALMANAGER/PRESIDENT IN CHARGE OF THE "ADANI PUBLIC SCHOOL, NANA KAPAYA, MUNDRA - KUTCH." LIABLE FOR ACTION.



FIRE OFFICER
Bhuj Nagarpalika
FIRE & EMERGENCY SERVICES
BHUJ NAGAR SEVA SADAN