



rfo-sfps-rajkot@gujarat.gov.in



**FORM B 13.3**  
**FIRE SAFETY CERTIFICATE RENEWAL (FSCR)**  
(See Rule 25)

**Fire Safety Certificate Approval (FSCA) No.** FSCA/O/RFORAJ/2024/00050190  
**FSC Safety Certificate Renewal (FSCR) No.** FSCA/O/RFORAJ/2024/00050190/R2

**Date:** 13/05/2026

**Building Occupancy/Category:** Educational (non-residential)

To,

PATADIA MAYUR KANAIYALAL  
- - NANA KAPAYA MUNDRA Mundra Kachchh 370415  
**Fire Region:** Rajkot RFO  
**Mobile No:** 9687605239 **Email ID:** Amrit.aps@adanischools.ac.in

We have received Application No. **2026/00178818** dated 23/03/2026 for **Fire Safety Certificate Renewal (FSCR)** - New Building(FSCR)/Existing Building (FSCRe) for the building/premise **ADANI PUBLIC SCHOOL (name of the Building/Project)**, as per below mentioned details:

- 1. TP Number:**
- 2. FP Number:**
- 3. Survey Number:** 23 AND 73
- 4. Village Name:** MUNDRA
- 5. Name of Block(s):** ADANI PUBLIC SCHOOL

The building/premise was inspected on **13/05/2026** and all fire prevention, life safety and fire protection measures provided were found to be in proper and effective working condition. There are no changes in building/premise use or occupancy or in building design or structure.

Further, the following activities (as applicable) have been carried out towards meeting requirements of GFP&LSM Act-2013, GFP&LSM Rules-2014 & GFP&LSM Regulations-2023 as amended, or the then applicable GDCR:

- Emergency drill was carried out on **06/05/2026 9:59:33 AM**
- Six monthly inspection was done on **28/04/2026 10:17:38 AM**

The Fire Safety Certificate is renewed for a period of **two (2)** years upto **13/05/2028** in accordance with GFP&LSM Act-2013, GFP&LSM Rules-2014 & GFP&LSM Regulations-2023 and their amendments.

This is issued based on the verification and approval of the RFO/CFO dated: **11/05/2026 4:08:55 PM**



**Digitally Verified**

Digitally verified by: Dipen Rajendrabhai Hansora  
Fire Safety Officer - General (FSO-G)  
2021/001355  
Reviewed by : RFO Rajkot  
Date: 13/05/2026  
Time: 11:48 AM



FSCA/O/RFORAJ/2024/00050190/R2

*This is a digitally verified certificate, hence doesn't require physical signature. To validate authenticity of this certificate, scan the QR code or search the certificate details in appropriate section at [www.gujfiresafetycop.in](http://www.gujfiresafetycop.in).*

*Please note that, apart from renewal, the building needs to be inspected every six months and a mock fire and emergency drill also needs to be conducted every six months. If there is a delay in scheduled inspection or mock drill, penalty shall be imposed. The Fire Safety Certificate renewal should be done timely after two years to avoid penalties.*